
CERTIFICATE OF APPROVAL
No. ME0205

This is to certify that the referenced products of

EVERBUILD BUILDING PRODUCTS

Site 41, Knowsthorpe Way, Cross Green Industrial Estate, Leeds, LS9 0SW
Tel: 0113 240 3456 Fax: 0113 240 0024

have been assessed against the requirements of the Warrington Certification Limited Middle East Certification Scheme and are approved for use within the scope of the test and/or assessment report(s) referenced.

Pyromate/Fireseal 400 Sealant Linear Joint Seals

Up To 300 Minutes Integrity & 240 minutes Insulation Performance In
Accordance With BS EN 1366-4: 2006

Report Reference	Valid Until
WF Test Report No. 181970	Not applicable
WF Test Report No. 181968	
WF Assessment Report No. 182723/B	1 st May 2014



CERTIFICATE OF APPROVAL
No. ME0205

Pyromate/Fireseal 400 Sealant Linear Joint Seals

**Up To 300 Minutes Integrity & 240 minutes Insulation Performance In
Accordance With BS EN 1366-4: 2006**

Wall Seals (seal to both faces of wall)

Gap Width mm	Seal width/ depth ratio	Backing material	Gap face material	Integrity mins	Insulation mins
12-50	2:1	PE open cell foam	AAC/AAC	300	180
12			AAC/Softwood	180	120
13-49				120	120
50				240	240
12-29				120	120
30-50			AAC/Hardwood	240	240
12-29				300	60
30-49				300	90
50			AAC/Steel	300	120

Floor Seals (seal to top surface of floor)

Gap Width mm	Seal width/ depth ratio	Backing material	Gap face material	Integrity mins	Insulation mins
12-30	2:1	PE open cell foam	AAC/AAC	240	120
31-50				240	60
12-30			AAC/Steel	300	30
31-50				180	30

AAC - Autoclaved aerated concrete
PE - Polyethylene

CERTIFICATE OF APPROVAL
No. ME0205

Pyromate/Fireseal 400 Sealant Linear Joint Seals

**Up To 300 Minutes Integrity & 240 minutes Insulation Performance In
Accordance With BS EN 1366-4: 2006**

Supporting Constructions	
Floors	Aerated concrete/concrete minimum 150 mm thick
Walls	Autoclaved Blockwork/aerated concrete/concrete/masonry minimum 150 thick
Installation	
Sealant to be applied onto a Polyethylene backing rod to achieve the correct depth within the linear joint, to the top surface of the supporting floor or to both faces of the supporting wall	

Certification is awarded on the basis of initial type testing to BS EN 1366-4: 2006, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by Warrington Certification Limited. The currency of the certification may be verified at www.warringtonfire.net/mideast.

Signed for and on behalf of Warrington Certification



Sir Ken Knight
Chairman - Management Council

Issued: 19th October 2009
Valid to: 1st May 2014